

CERTIFICATE of Conformity



Certificate No.: MK 69241308 0001

Test Report No.: 28212371 001

Certificate Holder: VENTILATION SYSTEMS PrJSC
1, Mikhaila Kotzubinskiego str.
UA-01030 Kiev
Ukraine

Manufacturer: VENTILATION SYSTEMS PrJSC
36, 40-richchya Zhovtnya str.,
UA-08150 Boyarka, Kiev region
Ukraine

Product: FANS
Centrifugal fans

Identification:

Type designation:	Rated power input:
VENTS KSA 100-2E yyyz ,	115W
VENTS KSA 125-2E yyyz ,	120W
VENTS KSA 150-2E yyyz ,	260W
VENTS KSA 160-2E yyyz ,	260W
VENTS KSA 200-4E yyyz ,	110W
VENTS KSA 250-4E yyyz ,	395W
VENTS KSA 315-4E yyyz	570W

Rated voltage: 230V~, 50Hz
Protection class: I
Degree of protection: IPX2
Where yyy= blank, U, Un, U1, U1n (Function)
z= blank, R (R= with supply cord and plug)

Tested according to: 2006/95/EC Annex 1
EN 60335-2-80:2003+A1+A2
EN 60335-1:2002+A1+A11+A2+A12+A13+A14
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2011.11.03

